



TC-13089

District Level Water Analysis Laboratory Aligarh

Address: First Floor, Office of Superintending Engineer U.P. Jal Nigam (Urban) Aligarh 202001

Water Test Report

Report No:	x ALIPst/Apr/009/2025-26 Issue Date: 08/04/2025							
UTR No.	TC1308925/Apr./009A Page No · 01							01
Customer Details								
Office Nat	me and Address		SETH M, R. JAIPURIA SCHOOL					
Ref Letter	No & Date		APP/Testing/04-04-2025					
				Basi	ic details of san	nple		
District			Aligarh		Block	Block		-
Gram Panchayat			-		Village / 1	Village / NPP		-
Habitation			School		Location	Location		Seth M. R. Jaipuria School, 9 KM Milestone, Mukundpur, Opp. The Radhavann Hotel & Convention Centre, Agra Road, Aligarh (U.P.)
Water Sou	rce		R O Water		Sample N	Sample No.		01
Quantity of Sample			1000 ml		Date of C	Date of Collection		04/04/2025
Receiving	Date		04/04/2025		Sample, C	ple. Collector		Mr. Sachin Gautam
Sample De	positor		Mr. Sachin (Gautam	Sampling	Sampling Method		As per IS 17614: Part 1:2021 & APHA 24th Edition
Analysis S	tart Date		07/04/2025		Analysis	Analysis Completion Date:		08/04/2025
Technical Data of Analysis								
S.No.	Analyzed parameters	(Unit of Measurement)	Observed Value	Acceptable Limit	Permissible Limit	Ref. Method of Analysis		
1	2	3	4	5	6	7		
1	рН	-	7.68	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)		
2	Turbidity	NTU	0.76	1	5	IS 3025 (Pt 10):2023		
3	TDS	mg/L	118	500	2000	IS 3025 (Pt 16):2023		
4	Fluoride	mg/L	0.05	1	1.5	APHA 24 rd Edition 4500-F Method C (Electrode method) 2023		
. 5	Total Hardness	mg/L	64	200	600	IS 3025 (Part 21):2019		
6	Total Alkalinity	mg/L	92	200	600	IS 3025 (Part 23):2023		
7	Chloride	mg/L	9.7	250	1000	IS 3025 (Part 32):2019		
8	Iron	mg/L	0.01	1	1	APHA 24 rd Edition 3500-Fe Method B (Phenanthroline Method) 2023		
9	Sulphate	mg/L	3.8	200	400	APHA 24 rd Edition 4500-SO4 Method E (Turbidity Method) 2023		
10	Calcium	mg/L	8.01	75	200	IS 3025 (Part 40):2023		
11	Magnesium	mg/L	10.7	30	100	IS 3025 (Part 46):2019		
12	Nitrate	mg/L	1.2	45	45	APHA 24 rd Edition 4500-NO3 Method D (UV Screening Method) 2023		
13	Colour (Hazen)	-	1	5	15	IS 3025 (Part 4): 2021		
14	Odour	-	Agreeable	-	-	IS 3025 (Part 05):2022		
15	Taste	-	Agreeable	-	-	IS 3025 (Part 08):2023		

Note

- This Certificate refers only to the sample(s) submitted for testing.
- 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
- 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 8. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.
- 5. Remark-Parameters above permissible limits are written in Bold.

Sample not Collected by Laboratory.

SETH M.R. JAIPURIA SCHOOL

MANAGER

Prepared By

Yashwant Singh (Deputy Technical Manager)

Laboratory Contact details

Email-waterlab.alig@gmail.com

Annexure C

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE Dated 08/04/2025 No. 09...

It is certified that an inspection headed by Shri Anil Kumar (Assistant Engineer (Sws n) (Name of Officers with designation) from Uttar Provish 1 at Nijam (Rural) PHED Aligarh inspected the Seth M. R. Jaipuria School, Aligarn (V.P.) (Name & Address of the school) on. ON 109 2025. (date of inspection) and on the basis of Water Test Report (Attached bearing no ALT PV+ APY 1009 12025-26 dated . 0.8 04 2025 of District Level water Analysis Laboratory, Aligarh (PHED Lab) certified that the Seth. M.R. Jaipuria School, Augerh (U.P.) (Name of school has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T Govt.

This certificate is valid till O1 Year

Signature with Seal:

Name

Designation

Name & Address of the Office/ Departmen

Uttar Product Jal Nigam (Ryrad)

Aligarh

Seth MR. Jaipuria School, Mame & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/Local bodies

SETH M.R. JAIPURIA SCHOOL